

Certificate of compliance

with the requirements of the standard CEI 0-21

CERTIFICATION Bureau Veritas Consumer Products Services Germany GmbH

ORGANIZATION: Accreditation to DAkkS, D-ZE-12024-01-00, ref. to DIN EN ISO/IEC 17065

STANDARD / GUIDE: CEI 0-21: 2019-04

CEI 0-21: V1: 2020-12 Edition December 2020

Reference technical rules for the connection of active and passive users to the LV electrical Utilities

TYPE OF SYSTEM DECLEARED:

INTERFACE DEVICE			ROTATING GENERATION MACHINE		
X	X	X			

MANUFACTURER: Ningbo Sunways technologies Co., Ltd.

No. 1, Second Road, Green Industrial Zone, Chongshou Town,

Cixi City, ZheJiang Province

PEOPLE'S REPUBLIC OF CHINA

PRODUCT TYPE:	Photovoltaic Inverter					
MODEL:	STS-1KTL-S	STS-1.5KTL-S	STS-2KTL-S	STS-2.5KTL-S	STS-3KTL-S	
NOMINAL POWER [kW]:	1,0	1,5	2,0	2,5	3,0	

FIRMWARE VERSION: beginning with V1.00

PHASE NUMBER: Single-Phase

NOTE:

The device is able to limit the ldc to 0,5% of the nominal current.

The device is for systems up to 11,08kW

The inverters of Ningbo Sunways technologies Co., Ltd. have a maximum apparent power limit. In the case where a system should be able to reach in every working condition a determined power factor, it is necessary to set the maximum active power in such a way, that you can reach at any time the $\cos \varphi$ wanted.

LABORATORY THAT HAS DONE THE TESTING:

Bureau Veritas Consumer Products Services Germany GmbH

Accreditation to DAkkS, D-PL-12024-03-03, ref. to DIN EN ISO/IEC 17025

After verifying the ISO 9001 of the Manufacturer with No. 02819Q11035R0S, issued by Benjing Zhong-An-Zhi-Huan Certification Center Co., Ltd. and verifying the test reports according to CEI 0-21 with No. CEXQ-ESH-P21123032, issued by the laboratory Bureau Veritas Consumer Products Services Germany GmbH and verifying the EMC test report with No. 4861920246800, issued laboratory TÜV SÜD Certification and Testing (China) Co., Ltd. accredited by CNAS (No. L2282) and No. J21-174-WT, issued laboratory SiTiiAS accredited by CNAS (No. L0130), the listed product(s) are conform with the requirements according to CEI 0-21: 2019-04, CEI 0-21: V1: 2020-12.

Certificate number: U22-0006

0000 00 40

Certification Program:

NSOP-0032-DEU-ZE-V01

Data of issue: 2022-03-18

Certification body

Thomas Lammel

Certification body Bureau Veritas Consumer Products Services Germany GmbH accreditation to DIN EN ISO/IEC 17065

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH



Annex to the CEI 0-21 certificate of compliance No. U22-0006

Table Interface Protection System (SPI)						
Extracts from test report				No. CEXQ-E	SH-P21123032	
Photovoltaic Invert	er					
Manufacturer:	Ningbo Sunways technologies Co., Ltd. No. 1, Second Road, Green Industrial Zone, Chongshou Town, Cixi City, ZheJiang Province PEOPLE'S REPUBLIC OF CHINA					
Model:	STS-1KTL-S	STS-1.5KTL-S	STS-2KTL-S	STS-2.5KTL-S	STS-3KTL-S	
Nominal Power [kW]:	1,0	1,5	2,0	2,5	3,0	
Firmware version:	Beginning with V1.00					
Number of phases (single-phase/three-phase):	Single-Phase					

Interface Protection System (SPI)

Temperature Ambient		Intervention thresholds		Time of intervention		Reset Ratio		Time of relapse		
		Detected	Requested	Detected	Requested	Detected	Requested	Detected	Requested	
		[V]	[V] ± 1%	[ms]	[ms]			[ms]	[ms]	
Voltage	Min	195,8	195,5	1546	1500 ± 20	N/A	1,03 ≤ r ≤ 1,05	N/A	40 ≤tr ≤ 100	
Threshold	Max	265,4	264,5	212	200 ± 20	N/A	0,95 ≥ r ≥ 0,97	N/A	40 ≤tr ≤ 100	
Temperature -10 °C		Interventio	n thresholds	s Time of intervention		Reset Ratio		Time of relapse		
		Detected [V]	Requested [V] ± 1%	Detected [ms]	Requested [ms]	Detected	Requested	Detected [ms]	Requested [ms]	
Voltage	Min	195,7	195,5	1473	1500 ± 20	N/A	1,03 ≤ r ≤ 1,05	N/A	40 ≤tr ≤ 100	
Threshold	Max	265,4	264,5	191	200 ± 20	N/A	0,95 ≥ r ≥ 0,97	N/A	40 ≤tr ≤ 100	
	Temperature		Intervention thresholds		Time of intervention		Reset Ratio		Time of relapse	
+55 °C		Detected [V]	Requested [V] ± 1%	Detected [ms]	Requested [ms]	Detected	Requested	Detected [ms]	Requested [ms]	
Voltage	Min	195,7	195,5	1457	1500 ± 20	N/A	1,03 ≤ r ≤ 1,05	N/A	40 ≤tr ≤ 100	
Threshold	Max	265,4	264,5	191	200 ± 20	N/A	0,95 ≥ r ≥ 0,97	N/A	40 ≤tr ≤ 100	

Note:

- ≤ 1 % for the voltage thresholds
- \leq 3 % ± 20 ms for the times of intervention

variation of the error during the repetition of the tests

- ≤ 2 % for the tensions
- \leq 1 % ± 20 ms for the times of intervention



Annex to the CEI 0-21 certificate of compliance No. U22-0006

Table Interfac	e Protec	ction Syste	m (SPI)							
Extracts from	test rep	ort					No	. CEXQ-ES	H-P21123032	
Frequency 49	,8Hz	50,2Hz								
Temperature Ambient		Intervention thresholds		Time of intervention		F	Reset Ratio	Time of relapse		
		Detected [Hz]	Requested [Hz] ± 20 mHz	Detected [ms]	Requested [ms]	Detected	Requested	Detected [ms]	Requested ms]	
Frequency	Min	49,81	49,80	103	100 ± 20 ms	N/A	1,001 ≤ r ≤ 1,003	N/A	40 ≤tr ≤ 100	
Threshold	Max	50,20	50,20	104	100 ± 20 ms	N/A	0,997 ≥ r ≥ 0,999	N/A	40 ≤tr ≤ 100	
Tempera		Intervention thresholds		Time of intervention		Reset Ratio		Time of relapse		
-10 °C		Detected [Hz]	Requested [Hz] ± 20 mHz	Detected [ms]	Requested [ms]	Detected	Requested	Detected [ms]	Requested ms]	
Frequency	Min	49,79	49,80	105	100 ± 20 ms	N/A	1,001 ≤ r ≤ 1,003	N/A	40 ≤tr ≤ 100	
Threshold	Max	50,20	50,20	102	100 ± 20 ms	N/A	0,997 ≥ r ≥ 0,999	N/A	40 ≤tr ≤ 100	
Tempera		Intervention thresholds		Time of intervention		Reset Ratio		Time of relapse		
+55 °C		Detected [Hz]	Requested [Hz] ± 20 mHz	Detected [ms]	Requested [ms]	Detected	Requested	Detected [ms]	Requested ms]	
Frequency	Min	49,79	49,80	83	100 ± 20 ms	N/A	1,001 ≤ r ≤ 1,003	N/A	40 ≤tr ≤ 100	
Threshold	Max	50,20	50,20	104	100 ± 20 ms	N/A	0,997 ≥ r ≥ 0,999	N/A	40 ≤tr ≤ 100	
Frequency 47	,5Hz	51,5Hz								
Tempera		Interventio	n thresholds	Time of intervention		F	Reset Ratio	Time of relapse		
Ambient		Detected [Hz]	Requested [Hz] ± 20 mHz	Detected [ms]	Requested [ms]	Detected	Requested	Detected [ms]	Requested ms]	
Frequency	Min	47,51	47,50	113	100 ± 20 ms	N/A	1,001 ≤ r ≤ 1,003	N/A	40 ≤tr ≤ 100	
Threshold	Max	51,49	51,50	112	100 ± 20 ms	N/A	0,997 ≥ r ≥ 0,999	N/A	40 ≤tr ≤ 100	
Tempera		Intervention thresholds		Time of intervention		Reset Ratio		Time of relapse		
-10 °C		Detected [Hz]	Requested [Hz] ± 20 mHz	Detected [ms]	Requested [ms]	Detected	Requested	Detected [ms]	Requested ms]	
Frequency	Min	47,51	47,50	106	100 ± 20 ms	N/A	1,001 ≤ r ≤ 1,003	N/A	40 ≤tr ≤ 100	
Threshold	Max	51,49	51,50	115	100 ± 20 ms	N/A	0,997 ≥ r ≥ 0,999	N/A	40 ≤tr ≤ 100	
Temperature +55 °C		Interventio	Intervention thresholds		Time of intervention		Reset Ratio		Time of relapse	
		Detected [Hz]	Requested [Hz] ± 20 mHz	Detected [ms]	Requested [ms]	Detected	Requested	Detected [ms]	Requested ms]	
Frequency	Min	47,51	47,50	108	100 ± 20 ms	N/A	1,001 ≤ r ≤ 1,003	N/A	40 ≤tr ≤ 100	
Threshold	Max	51,49	51,50	100	100 ± 20 ms	N/A	0,997 ≥ r ≥ 0,999	N/A	40 ≤tr ≤ 100	

Note:

- ± 20 mHz for the frequency thresholds
- \leq 3 % ± 20 ms for the times of intervention

variation of the error during the repetition of the tests

- \leq 1 % \pm 20 ms for the times of intervention